

REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

Certificate

No. 89-----

DATE 11/06/2026-----

It is certified that an inspection team headed by— *Mr. Jai Kishan Kumar*
(Assistant Chemist) from *P. H. Division Bhagalpur East, Bhagalpur*
inspected the *D.L.S International Public School, Badluganj Barahat*
Ishipur, Bhagalpur on *06.06.2026* and found the *D.L.S*
International Public School, Badluganj Barahat Ishipur, Bhagalpur
has safe drinking water facilities for the students and members of staff institution and is
maintaining the hygienic sanitation condition in the school campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of- *One Year (11.06.2026 to 10.06.2027)*.

Signature With Seal:-

Name

Sanjay K. Paswan

Designation :-

Assistant Research Officer



To,

*D. L. S International Public School,
Badluganj Barahat Ishipur,
Bhagalpur
Bihar-813206*

Government Of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department,

Bhagalpur

Ref.No. EE-1999 Dt- 04.06.2026

Date of Sampling - 06.06.2026

Name of School :- D.L.S International Public School

Sample Collected By- Lab Staff

Source of Sample- R.O water

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT																						
S.No.	Location					Physico - Chemical and Bacteriological Parameters																Remarks
	Block	Panchayet	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Microbial		
1	D.L.S International Public School Badluganj,Barahat, Bhagalpur-813206					7.92	0.80	257.0	128.0	65.2	26.1	8.70	31.9	57.4	0.08	3.18	6.5	0.05	NA	Negative		
	Desirable Limit*					6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-		
	Permissible Limit* in absence of alternate source					NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**		
NA=Not Applicable																						

NA=Not Applicable

Memo No.... RL-89

Date 11/06/2026

Copy Forwarded To : 1. Executive Engineer, P.H.Division Bhagalpur East, for kind information and necessary action.

Suman
11/06/26
Lab Incharge(A.R.O)